



CERTIFICATE

KEMA No.: 2125286.04

Issued to:
Applicant:

B.V. Wavin KLS
J.C. Kellerlaan 8
7772 SG Hardenberg
The Netherlands



Manufacturer/Licensee:

B.V. Wavin KLS
J.C. Kellerlaan 8
7772 SG Hardenberg
The Netherlands

Product : Conduit systems for cable management
Trade name : WAVIN
Types : Pliable conduit systems; WM16, WM25 and WM32

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

KEMA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61386-1:2008 and EN 61386-22:2004;
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900429

KEMA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 22 April 2009 and expires upon withdrawal of one of the above mentioned standards.

KEMA Quality B.V.

drs. G.J. Zoetbrood
Managing Director

H.R.M. Barends
Certification Manager

ACCREDITED BY
THE DUTCH COUNCIL
FOR ACCREDITATION



© Integral publication of this certificate is allowed

**SPECIFICATION OF THE CERTIFIED PRODUCT****Product data**

product	:	Conduit systems for cable management
trade name	:	WAVIN
type	:	Pliable conduit systems; WM16, WM25 and WM32
material	:	PVC compound
resistance to compression	:	3
resistance to impact	:	3
lower temperature range	:	2
upper temperature range	:	1
resistance to bending	:	2
resistance to flame propagation	:	1
tested conduits	:	16mm and 32mm
certified conduits	:	16mm, 25mm and 32mm

TESTS**Test requirements**

EN 61386-1:2008 and EN 61386-22:2004

Test result

The test results are laid down in KEMA test file 2125286.04.

Remarks

This KEMA-KEUR certificate is based on and supersedes KEMA-KEUR certificate no. 2070600.01, dated January 26, 2004.

Conclusion

The examination proved that all test requirements were met.

Tested by : R. van Daalen Checked by : A.A. Mackenbach 