

CERTIFICATE

Issued to:
Applicant:
Wavin Nederland B.V.
J.C. Kellerlaan 8
7772 SG Hardenberg
The Netherlands

Manufacturer/Licensee:
Wavin Nederland B.V.
J.C. Kellerlaan 8
7772 SG Hardenberg
The Netherlands

Product : Conduit systems for cable management
Trade name : WAVIN
Type : Rigid conduit systems (Low Friction)

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard DEKRA K24D-10:2011
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900429

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on: 31 August 2016 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 2195523.02

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

product	:	Conduit systems for cable management
trade name	:	WAVIN
type	:	Rigid conduit systems (Low Friction)
material	:	PVC compound
resistance to compression	:	3
resistance to impact	:	3
lower temperature range	:	3
upper temperature range	:	1
resistance to bending	:	1
resistance to flame propagation	:	1
tested conduits	:	5/8" and 3/4" Low Friction
certified conduits	:	5/8" and 3/4" Low Friction

TESTS**Test requirement**

DEKRA K24D-10:2011

Test result

The test results are laid down in DEKRA test file 2195523.02.


Remarks

This KEMA-KEUR certificate is also based on and replaces KEMA-KEUR certificate 2147809.01 of 9 September 2011.

Conclusion

The examination proved that all test requirements were met.

Tested by : R. van Daalen
Checked by : A.A. Mackenbach

**Factory location**

Wavin Nederland B.V.
J.C. Kellerlaan 8
7772 SG Hardenberg
The Netherlands